



Farabaugh Engineering and Testing Inc.

September 21, 2012

Custom Metal Components, Inc.
420 W. Lingleville Rd.
Stephenville, TX 76401

Attn: Vince Daddio

Re: Roof Vent Air Tests

The purpose of this letter is to provide a summary of testing on the above referenced project.

Test Standard Procedure : ASTM E283 Air Test

FET Project No. T303-12

Test Specimen A: Original Vent Design (Larger Openings)
Test Specimen B: Alternate Vent Design (Smaller Openings)
Test Specimen C: Alternate Vent Design – Rev. 1 (Medium Openings)

TEST SPECIMEN	TEST PRESSURE (PSF)	TEST PRESSURE (Pa)	AIR EXFILTRATION (CFM)
A	1.57	75.17	69.4
A	6.24	298.77	153.2
B	1.57	75.17	22.8
B	6.24	298.77	47.7
C	1.57	75.17	49.3
C	6.24	298.77	104.6

Note: Testing was on a 1' length of vent.

If you have any questions, please contact the undersigned.

Sincerely,

Patrick J. Farabaugh
Vice President

